

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


No.F6/DFS/MS/2019/ School/NDZ/ 2086

Dated: 30/10/19

FIRE SAFETY CERTIFICATE

Certified that the Nava Hind Girls Sr. Sec. School located New Rohtak Road, New Delhi-05 comprises of Ground + 01 Upper floor only (except Auditorium/Hall) owned/occupied by Nava Hind Girls Sr. Sec. School have complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of this department on 09-08-2019 in the presence of Principal and that the building premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from 30/10/2019 for a period of three years subject to compliance of the conditions mentioned below:

Issued on30/10/19..... at New Delhi by.



(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal,
Nava Hind Girls Sr. Sec. School,
New Rohtak Road, New Delhi-05.
2. Director of Education,
Govt. of NCT, Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".


Principal
Nava Hind Girls Sr. Sec. School
New Rohtak Road, New Delhi