

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2022/ School/NDZ/ 1290

Dated: 01/12/2022

FIRE SAFETY CERTIFICATE

Certified that the Nava Hind Girls Sr. Sec. School located New Rohtak Road, New Delhi-05 comprises of Ground + 01 Upper floor only (except Auditorium/Hall), was earlier granted FSC by this department vide letter No.F6/DFS/MS/2019/school/NDZ/2086 dated 30/10/2019. Now, the premises was re-inspected by the officer concerned of this department on 22-11-2022 in the presence of Miss. Seema Kharbanda and found that school has deemed complied with the fire prevention and fire safety requirements in accordance with circular of director of education dated and the primisies found fit for the occupancy Group B "Educational Building" (except Auditorium/Hall), (Sub-Div. B-I) with effect from...01/12/2022 for a period of three years subject to compliance of the conditions mentioned below:

Issued on ...01/12/2022 at New Delhi by.

(Signature)
30/11/22

(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.
2. The Principal, Nava Hind Girls Sr. Sec. School, New Rohtak Road, New Delhi-05.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned .
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

(Signature)
19/8/23

Vice Principal
Nava Hind Girls Sr. Sec. School
New Rohtak Road, New Delhi-05

(Signature)
19/8/23

Manager
Nava Hind Girls Sr. Sec. School
New Rohtak Road, New Delhi-05